



SCHOOL: \_\_\_\_\_ IMMEDIATE NEEDS:

**PASADENA HS**

**PRIORITY 2**

- A. DEFINE MAIN ENTRY TO CAMPUS WITH ARCHITECTURAL FEATURES AND DIRECTIONAL SIGNAGE SYSTEM THROUGHOUT. DECREASE POROSITY OF CAMPUS BY INSTALLATION OF TUBULAR STEEL FENCING WHERE APPLICABLE.
- B. POOL AREAS NEED: REPLACEMENT OF ELECTRICAL SYSTEM; REPLACEMENT OF CONCESSION STANDS; REPLACEMENT OF PIPING SYSTEM; REPLACEMENT OF PERIMETER TRANSITE POOL FENCE; RESURFACE ALL POOLS FROM FIBERGLASS-LINED TO PLASTER.
- C. STUDY SCHOOL'S PARKING AREAS AND RECONFIGURE EXISTING TO CREATE NEW AND EQUALLY DISPERSED LOTS. PRESENT MAIN VISITOR PARKING IS TOO DISTANT FROM ADMINISTRATION OFFICES.
- D. INCREASE SIZE OF ADMINISTRATION SPACE.
- E. IMPROVE EXTERIOR APPEARANCE OF BUILDINGS INCLUDING REPAIR OR REPLACEMENT OF WINDOWS.
- F. UPGRADE AND/OR BALANCE HVAC SYSTEM IN ALL BUILDINGS EXCEPT GYM AND AUDITORIUM. RECOMMEND A SPLIT HVAC SYSTEM AT BUILDING 'A'.
- G. HAZARDOUS MATERIALS: CONCERN IS PIPE INSULATION IN GYM.WATER HEATER ROOM (URGENT) THE REMAINING 7 LOCATIONS RANKING 4 THROUGH 6 ARE TYPICALLY PIPE INSULATION OR FLOOR TILE, AND OCCUR AT THE GYM, LOCKER ROOM OR RESTROOM IN BUILDING H.



- H. PROVIDE METAL BLEACHERS AT FIELD AND BUDGET FOR NECESSARY MAINTENANCE OF SPORTS FIELDS AND FACILITIES.
- I. UPGRADE ANTIQUATED TELEPHONE SYSTEM CAMPUS WIDE.
- J. REPAIR EXPANSION JOINT BETWEEN BLDGS. 'G', 'H', 'I' AND 'E' TO PREVENT WATER SEEPAGE.
- K. REPAIR IRRIGATION SYSTEM FOR FIELD AND CAMPUS LANDSCAPING, PROVIDE ADDITIONAL IRRIGATION AS NEEDED.
- L. REPLACE RUSTY CHAIN LINK FENCING AT SPORTS FIELDS AND TENNIS COURTS.