



SCHOOL: **WASHINGTON MS** IMMEDIATE NEEDS:

- A. RECONSTRUCT ENTIRE GYM WITH NEW CURRENT ELECTRICAL, MECHANICAL, LIGHTING, ACOUSTICAL, TECHNOLOGICAL, AND INTERIOR FINISH STANDARDS. MODERNIZATION WILL INCLUDE STRUCTURAL UPGRADING.
- B. MODERNIZE AUDITORIUM. INCLUDE REPLACEMENT OF RIGGING SYSTEM, CURTAIN AND ELECTRICAL SWITCH GEAR.
- C. MODERNIZE AND EXPAND CAFETERIA. INCLUDE PROVISION OF NEW LUNCH SHELTER AND TEACHERS' LOUNGE.
- D. MODERNIZE CLASSROOM BUILDING 'C'.
- E. REPAIR CLOCK, P.A., AND BELL SYSTEMS.
- F. REPAIR AND/OR REPLACE SECURITY FENCING WHERE NEEDED.
- G. PROVIDE NEW HVAC SYSTEM FOR THE AUDITORIUM, CAFETERIA, KITCHEN AND GYMNASIUM.
- H. REPLACE OLD ELECTRIC PANELBOARDS WITH ADEQUATE BRANCH BREAKERS WITH INCREASED CAPACITY.
- I. SEPARATE DOMESTIC, FIRE, AND IRRIGATION WATER METERS.
- J. REPAIR OR REPLACE FIRE ALARM / BELL SYSTEM.
- K. REPLACE FLOOR MOUNTED HEATERS IN BUILDING 'A' CLASSROOMS WITH NEW FLOOR OR WALL MOUNTED UNITS.

ESTIMATED COST OF IMMEDIATE NEEDS:

\$ 24,544,256